

CHAPTER 15 EMERGENCY SHELTERS FOR THE HOMELESS

5:15-4.2 Building standard requirements

(a) – (b) (No change.)

(c) A structure used as a shelter for women and children where residency is for 30 days or more, and which has not been certified as lead-free pursuant to N.J.A.C. 5:17 and which was constructed before 1978, shall be maintained in accordance with the lead safe maintenance requirements for multiple dwellings established at N.J.A.C. 5:10-6.6.